

OK Zavodu miru

Project : VO Karlovy Vary

File : ... \PP\Plocha\vypocet osvetleni.lpf


## Summary

### Grid summary

Average type : Arithmetic (A) or Weighted (W)



vypocetni plocha OK (1)	Min	Max	Ave (A)	Min/Max	Min/Ave
Illuminance (lux)	9,1	35,1	21,7	26,1	42,1



vypocetni plocha komunikace (2)	Min	Max	Ave (A)	Min/Max	Min/Ave
Illuminance (lux)	6,5	28,2	15,2	22,9	42,6

**Current view** Configuration (1)

**Grid results**

Average type : Arithmetic (A) or Weighted (W)

**vypocetni plocha OK (1) : Illuminance [lux]****vypocetni plocha OK (1) : Illuminance [lux]**

**vypocetni plocha komunikace (2) : Illuminance [lux]****vypocetni plocha komunikace (2) : Illuminance [lux]**

## General information

### Configuration details

#### • Configuration (1)

Activated ☒

Matrix	Description	Flux	MF	Luminaire
892805	C:\Program Files\Schreder\Lighting\Matrices\892805.mat	10,7	0,84	No Picture

#### Group details

Single								
	N°	Start			Luminaire			
		X	Y	H	Matrix	Az	Inc	Rot
✓	1	83,051	112,482	9,000	892805	-238,2	5,0	0,0
✓	2	100,169	114,792	9,000	892805	-145,4	5,0	0,0
✓	3	104,128	99,489	9,000	892805	-59,4	5,0	0,0
✓	4	82,350	90,456	9,000	892805	-235,8	5,0	0,0
✓	5	80,411	114,090	9,000	892805	-55,5	5,0	0,0
✓	6	63,129	71,441	9,000	892805	-224,2	5,0	0,0